

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 8165-2232:0500 Page 1 of 1

CATEGORY: 8165 -- VENTS FOR WILDLAND URBAN INTERFACE (W.U.I.)

LISTEE: Brandguard Vents 1001 Avenida Pico, Suite C #221, San Clemente, CA 92673
Contact: Kelly Berkompas (949) 481-5300
Email: kellyberkompas@yahoo.com

DESIGN: BrandGuard Vents Model UE 3011 (22"X3.5"), UE 3021 (14"X3.5"), UE 3031 (14"X3"), UE 3041 (22"X3"), UE 3051 (22"X5.5"), CS 3011 (120"X3"), CS 3021 (120"X5.5"), Undereave/Soffit Vent constructed of 26 gauge, hot dipped, galvanized sheet steel with phosphatized coating, galvanized 1/8" square mesh screen.

RATING: Rated for use as materials for exterior wildfire exposure in Wildland Urban Interface (WUI) fire areas.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee name, Model number, rating and SFM label.

APPROVAL: Listed as foundation vent, soffit vent, and eave vent for use in Wildland Urban Interface Areas (WUI) for vertical and horizontal installation only.

7-18-16 dc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division